



Declaration of Conformity

| For the fo | llowing | equipment |
|------------|---------|-----------|
|------------|---------|-----------|

Product Name: Switching Power Supply

Model Designation: LPP-100-x(x=3.3,5,7.5,12,13.5,15,24,27,48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:

RoHS Directive (2011/65/EU), (EU)2015/863

Low Voltage Directive (2014/35/EU):

TUV certificate No: R50453794 EN 62368-1:2014+A11

Electromagnetic Compatibility Directive (2014/30/EU):

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN 55032:2015+A1:2020 Class B

Harmonic current EN IEC 61000-3-2:2019+A1:2021

Voltage flicker EN 61000-3-3:2013+A1:2019

EMS (Electro-Magnetic Susceptibility)

EN 55035:2017+A11:2020

| EN 55055.2017+A11.2020 |) | | |
|--------------------------|-----------------------------------------------------------------------------------------|---------|----------------|
| ESD air | EN 61000-4-2:2009 | Level 3 | 8KV |
| ESD contact | EN 61000-4-2:2009 | Level 2 | 4KV |
| RF field susceptibility | EN IEC 61000-4-3:2020 | Level 2 | 3V/m |
| EFT bursts | EN 61000-4-4:2012 | Level 2 | 1KV/5KHz |
| Surge susceptibility | EN 61000-4-5:2014+A1:2017 | Level 3 | 1KV/Line-Line |
| Surge susceptibility | EN 61000-4-5:2014+A1:2017 | Level 3 | 2KV/Line-Earth |
| Conducted susceptibility | EN 61000-4-6:2014 | Level 2 | 3V |
| Magnetic field immunity | EN 61000-4-8:2010 | Level 2 | 3A/m |
| • | EN IEC 61000-4-11:2020 <5% residual voltage for 0.5 cycles ,70% residual voltage for 25 | | |

cycles, <5% residual voltage for 250 cycles: Voltage dip, interruption

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.

For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies" (as available on http://www.meanwell.com)" and TDF (Technical Documentation File).

This Declaration is effective from serial number SC1xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D:

(Name / Position)

Alex Tsai/ Director, Product Strategy Center: (Name / Position)

Taiwan

Sep. 22nd, 2021

(Place)

(Date)